



Jim Doyle, Governor
Mary P. Burke, Secretary

August 23, 2007

HUGHES CONCRETE PRODUCTS
MIKE HUGHES
D1871 CTY RD.C
STRATFORD WI 54484-9330

Re: Description: SEWAGE TANK, SITE CONSTRUCTED
Manufacturer: HUGHES CONCRETE PRODUCTS
Product Name: HOLDING TANK
Model Number(s): 250
(65" MAX L.L., 79.8 GAL./IN, 72" MAX. DEPTH OF BURY)
Product File No: 20070367

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of December 2012.**

This approval is contingent upon compliance with the following stipulation(s):

- The manufacturer must keep a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- This product is approved to use the following:
 - Pipe materials constructed in conformance with Table 84.30-2 or 84.30-11, Wis. Admin. Code poured into tank cover.
- This tank must be designed to withstand the pressures to which it will be subjected.
- This product is approved to use the following:
 - Four inch or Six inch inlet openings.
 - Inlet may be located in the side or end of the tank.
 - The liquid level of the tank may vary, but not to exceed 65 inches.

This approval supersedes the approval issued on 12/20/2002 under product file number 20020522.

A copy of a successful water tightness test report for this product must be submitted to this office prior to this product being used as a POWTS holding or treatment tank in Wisconsin.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Product Reviewer
Commerce; Safety & Buildings Div.
PO Box 2658; 201 W Washington Ave.; Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456; E-mail: Jean.MacCubbin@wisconsin.gov